

PAD MOUNT PRIMARY METERING CABINET REQUEST

COMPANY: _____ CONTACT NAME: _____

ADDRESS: _____ PHONE #: _____

_____ E-MAIL: _____

INITIAL PURCHASE QTY: _____ ANNUAL USE QTY: _____

1. NOMINAL VOLTAGE OF THE ENCLOSURE:

15kV/95kV BIL
25kV/125kV BIL

2. AMPERAGE:

200A
600A
OTHER _____

3. PHASE:

3 PHASE
SINGLE PHASE

4. DIMENSION:

3154 72"W x 54"D x 54"H
4690 54"W x 54"D x 45"H (15kV ONLY)
5454 54"W x 54"D x 52"H (15kV ONLY)
7624 79"W x 54"D x 54"H
7791 72"W x 56"D x 48"H

7254 72"W x 54"D x 54"H
7950* 79"W x 54"D x 58"H
7951** 79"W x 54"D x 58"H
7990* 48"W x 54"D x 42"H (SADTEM/KYE Pack)

*ELECTRAK SLIDING SHELF FEATURE

**ELECTRAK SLIDING SHELF FEATURE (TOP ONLY)

5. BUSHINGS REQUIRED PER EACH PHASE:

200 AMP BUSHING WELL
QTY: _____ LINE _____ LOAD PER PHASE

W/ BUSHING INSERT

600 AMP BUSHING
QTY: _____ LINE _____ LOAD PER PHASE

6. ARE TRANSFORMERS REQUIRED:

YES

NO

VOLTAGE TRANSFORMERS:

PREFERRED MANUFACTURER: _____

TYPE: _____ PART # _____

PRIMARY/SECONDARY VOLTAGE: _____

CURRENT TRANSFORMERS:

PREFERRED MANUFACTURER: _____

TYPE: _____ PART # _____

ACC CLASS: 0.3 0.15 0.155

RATIO: _____ RF: _____

7. MOUNTING:

CTS MOUNTED FROM THE CEILING AND VTS AT GROUND LEVEL (STD)

OTHER _____

PAD MOUNT PRIMARY METERING CABINET REQUEST

8. DO YOU WANT PRIMARY CONNECTIONS BETWEEN THE BUSHING AND THE TRANSFORMERS

YES

NO

9. IS SECONDARY WIRING DESIRED?

YES

NO

*IF YES PLEASE ATTACH WIRING DIAGRAM WITH WIRE COLORS.

10. WIRE PREFERENCE:

#12 GAUGE THHN STRANDED (STD)
OPTIONAL PLASTIC CONDUIT

#12 GAUGE THHN SOLID
OTHER _____

11. METER SOCKET REQUIRED?

YES

NO

*IF YES SEE BROOKS PRE-WIRED METER SOCKET REQUEST FORM FOR SPECIFIC METER SOCKET REQUIREMENTS

12. PLEASE SPECIFY OTHER FEATURES, SPECIFICATIONS AND/OR SPECIAL NEEDS:

***RETURN TO BROOKS CSR EMAIL OR SALES@BROOKSUPG.COM**