

PAD MOUNT PRIMARY METERING CABINET REQUEST

COMPANY: _____ CONTACT NAME: _____

ADDRESS: _____ PHONE #: _____

E-MAIL: _____

INITIAL PURCHASE QTY: _____ ANNUAL USE QTY: _____

1. NOMINAL VOLTAGE OF ENCLOSURE:

15kV/95kV BIL
25kV/125kV BIL
35 kV/150kV BIL

2. AMPERAGE:

200A
600A
OTHER _____



3. DIMENSIONS:

5454 54"W x 54"D x 52"H (15kV ONLY)
7624 79"W x 54"D x 54"H (15-25kV)
7950* 79"W x 54"D x 58"H (15-25kV)
7951** 79"W x 54"D x 58"H (15-25kV)
10266 102"W x 66"D x 60"H (35kV)

STANDARD FEATURES:

ALL MODELS ARE 3-PHASE.

*ELECTRAK SLIDING SHELF FEATURE

**ELECTRAK SLIDING SHELF FEATURE (TOP ONLY)

4. BUSHINGS REQUIRED PER EACH PHASE:

200 AMP BUSHING WELL W/ BUSHING INSERT
QTY: _____ LINE _____ LOAD PER PHASE

600 AMP BUSHING
QTY: _____ LINE _____ LOAD PER PHASE
(BUSHING INSERT INCLUDED)

5. ARE TRANSFORMERS REQUIRED: YES NO

IF YES, PROVIDED BY WHICH PARTY: BROOKS CUSTOMER

VOLTAGE TRANSFORMERS:

PREFERRED MANUFACTURER: _____

TYPE: _____ PART # _____

PRIMARY /SECONDARY VOLTAGE: _____

CURRENT TRANSFORMERS:

PREFERRED MANUFACTURER: _____

TYPE: _____ PART # _____

ACC CLASS: 0.3 0.15 0.155

RATIO: _____ RF: _____



43045 WEST NINE MILE ROAD
NOVI, MI 48375
1.888.687.3008
EMAIL: SALES@BROOKSUPG.COM
WWW.BROOKSUTILITY.COM
VERSION 1.2026

PAD MOUNT PRIMARY METERING CABINET REQUEST

6. DO YOU REQUIRE PRIMARY CONNECTIONS BETWEEN BUSHINGS AND TRANSFORMERS?

YES

NO

7. IS SECONDARY WIRING DESIRED?

YES

NO

*IF YES PLEASE ATTACH WIRING DIAGRAM WITH WIRE COLORS.

8. WIRE PREFERENCE

#12 GAUGE THHN STRANDED (STD)

OPTIONAL PLASTIC CONDUIT

OTHER _____

9. METER SOCKET REQUIRED?

YES

NO

*IF YES SEE BROOKS PRE-WIRED METER SOCKET REQUEST FORM FOR SPECIFIC METER SOCKET REQUIREMENTS

10. PLEASE SPECIFY OTHER FEATURES, SPECIFICATIONS AND/OR SPECIAL NEEDS:

*RETURN TO BROOKS CSR EMAIL OR SALES@BROOKSUPG.COM